Energy Performance Certificate for buildings other than dwellings

Energy Performance Certificate

Building Energy Performance — Scotland

Calculated asset rating using IES <VE> v6.1.1 [SBEM]	Building type Office	Current rating
		Excellent
	Carbon Neutral	
	A (0 to 15)	
	B (16 to 30)	
	C (31 to 45)	C
	D (46 to 60)	
	E (61 to 80)	
	F (81 to 100)	
	G (100+)	Very Poor

Carbon Dioxide Emissions The number refers to the calculated carbon dioxide emissions in terms of kg per m² of floor area per year	**45**
Approximate current energy use per m² of floor area:	**108** kWh/m²

Main heating fuel: Grid Supplied Electricity **Building Services:** Air conditioning

Renewable energy source: **Electricity:** Grid supplied

Carbon Dioxide is a greenhouse gas which contributes to climate change.
Less Carbon Dioxide emissions from buildings helps the environment.

Benchmarks

A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:	**59**	D
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:	**30**	B

Recommendations for the cost-effective improvement (lower cost measures) of the energy performance

1. Add optimum start/stop to the heating system.
2. Add weather compensation controls to heating system.
3. Consider installing building mounted wind turbine(s).
4. Consider replacing T8 lamps with retrofit T5 conversion kit.
5. Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.

Address: 33, Eliburn Business Park, Eliburn, WEST LOTHIAN, EH54 6GR
Conditioned area (m²): 547
Name of protocol organisation: Stroma Accreditation Ltd, [STRO001565]
Date of issue of certificate: 20 Oct 2010 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE